


## T SERIES TERMINAL BLOCKS

### Dimensions



Rated Insulation Voltage  $U_i$  600V



Type	Rated Current (600V)	Number of Poles	Dimensions (mm)								
			A	B	C	D	E	/TH	L	M	S
TK-010	10	Any	$16.8+D \times n$	38	33	8	7	4.5/35	$n \times 8+9.4$	3	16.7
TK-020	20		$16.8+D \times n$			9.8	8		$n \times 9.8+9.4$	3.5	16.2
TK-030	30		$16.8+D \times n$			11.6	10		$n \times 11.6+9.4$	4	18
TK-040	40		$16.8+D \times n$	13.6	12	$n \times 13.6+9.4$	4		18		
TK-060	60		$16.8+D \times n$	48	42.5	15.5	13		$n \times 15.5+9.4$	5	22.9
TK-100	100		$16.8+D \times n$	53	42.5	19.6	18		$n \times 19.6+9.4$	6	26

n Number of Poles

**TK**